

1        **The Impact of Neglecting Climate Change and Variability on ERCOT's**

2                                **Forecasts of Electricity Demand in Texas**

3

4                                **Jangho Lee and Andrew E. Dessler**

5        **Department of Atmospheric Sciences, Texas A&M University, College Station, TX, USA**

6

7

8

9        This work has been submitted to [Weather, Climate, and Society]. Copyright in this work may be  
10       transferred without further notice.

11

12       This work is published in [Weather, Climate, and Society]

13       <https://doi.org/10.1175/WCAS-D-21-0140.1>

14 Abstract

15 The Electric Reliability Council of Texas (ERCOT) manages the electric power across most of Texas.  
16 They make short-term assessments of electricity demand based on historical weather over the  
17 last decade or two, thereby ignoring the effects of climate change and the possibility of weather  
18 variability outside of the recent historical range. In this paper, we develop an empirical  
19 methodology to predict the impact of weather on energy demand. We use that with a large  
20 ensemble of climate model runs to construct a probability distribution of power demand on the  
21 ERCOT grid for summer and winter 2021. We find that the ERCOT grid is running with no safety  
22 margin, particularly during summer. We estimate a 5% chance that maximum power demand  
23 would be within 4.3 and 7.9 GW of ERCOT's estimate of best-case available resources during  
24 summer and winter 2021, respectively, and a 20% chance it would be within 7.1 and 17 GW. With  
25 such small margins, the unexpected reductions in available power can lead to shortages on the  
26 grid. This problem is partially hidden by the fact that ERCOTs seasonal assessments, based  
27 entirely on historical weather, are too low. Prior to the 2021 winter blackout, ERCOT forecasted  
28 an extreme peak load of 67 GW. In reality, we estimate hourly peak demand was 82 GW, 22%  
29 above ERCOT's most extreme forecast and about equal to the best-case available power. Given  
30 the high stakes, ERCOT should develop probabilistic estimates using modern scientific tools to  
31 predict the range of power demand more accurately.

## 32 1. Introduction

33 Most of the citizens of the State of Texas get electricity from a grid managed by the Electric  
34 Reliability Council of Texas (ERCOT). During February 2021, a significant winter storm (Doss-Gollin  
35 et al. 2021) caused widespread blackouts throughout the State that left more than 10 million  
36 people without electricity (Busby et al. 2021). These blackouts and their downstream impacts led  
37 to the deaths of hundreds of people and caused nearly \$200B of damages (Frankenfield 2021;  
38 Ivanova 2021).

39

40 To maintain the robustness of the grid, ERCOT makes short-term seasonal power-demand  
41 assessments (e.g., [http://www.ercot.com/content/wcm/lists/197378/SARA-FinalWinter2020-](http://www.ercot.com/content/wcm/lists/197378/SARA-FinalWinter2020-2021.pdf)  
42 [2021.pdf](http://www.ercot.com/content/wcm/lists/197378/SARA-FinalWinter2020-2021.pdf)) to ensure adequate resources will be available. These assessments are based on the  
43 weather from the past decade or so and factors such as population, but they do not account for  
44 a changing climate or the possibility of climate variability outside of the conditions described in  
45 the historical record. In this paper, we evaluate this methodology and develop a new method for  
46 incorporating more realistic predictions of future weather into energy projections.

47

## 48 2. The model ensemble and comparisons to historical data

49 Our observational data set is daily-average 2-m air temperatures from the ECMWF ERA5  
50 reanalysis (Hersbach et al. 2020), which has a resolution of 0.25° for both latitude and longitude.  
51 We also use temperatures from an ensemble of 39 model runs known as the Community Earth  
52 System Model Large Ensemble (CESM-LE) (Kay et al. 2015). The members of this ensemble use  
53 an identical climate model and the same evolution of historical natural and anthropogenic

54 forcing. The members differ only in their initial conditions, so the variation in climate across the  
55 ensemble is entirely due to random climate and weather variability.

56

57 To estimate the temperature of Texas, we average the grid points whose centers are within the  
58 state border of Texas. The ensemble is bias corrected by adding offsets of  $0.7^{\circ}\text{C}$  and  $0.6^{\circ}\text{C}$  to June-  
59 July-August season (JJA) and December-January-February season (DJF) to ensemble member  
60 temperatures so that the 40-year seasonal average temperatures from ERA5 is equal to the 40-  
61 year seasonal averages of the ensemble. This bias is small compared to the magnitude of the  
62 temperature variations we are analyzing.

63


64 Figure 1 shows the highest 1-day and 5-day average temperature during each JJA and lowest 1-  
65 day and 5-day average temperature during each DJF since 1981 in the ECMWF ERA5 reanalysis.  
66 The convention in this paper is that DJF refers to three consecutive months; for example, DJF  
67 2010 is Dec. 2009 and Jan. and Feb. 2010. For the JJA maximum, the highest 5-day average  
68 temperature was in 2011 ( $32.9^{\circ}\text{C}$ ) while the highest 1-day temperature ( $33.1^{\circ}\text{C}$ ) was in 2020. For  
69 the DJF minimum, the coldest 5-day ( $-6.3^{\circ}\text{C}$ ) and 1-day average temperature ( $-11.1^{\circ}\text{C}$ ) were both  
70 in 2021.

71

72 When comparing to the climate model ensemble, the appropriate comparison is between the  
73 statistics of the ensemble and the observations, and these agree closely (Figs. 1c and 1d). Fitting  
74 the ERA5 and CESM-LE data to a generalized extreme value (GEV) distribution tells us that the  
75 2020 1-day temperature of  $33.1^{\circ}\text{C}$  was a 1-in-7 year event in the ERA5, while it was a 1-in-5 year

76 event in CESM-LE. The 2021 winter 1-day temperature of  $-11.1^{\circ}\text{C}$  was a 1-in-55 year event in the  
 77 ERA5, while it was a 1-in-87 year event in the CESM-LE. The standard deviation of ERA-5 data is  
 78  $2.0^{\circ}\text{C}$  and  $4.9^{\circ}\text{C}$  in JJA and DJF, while the average of standard deviation in each member of CESM-  
 79 LE is 1.8 ( $1\sigma$  of ensemble standard deviation values is 0.22) and 4.0 ( $1\sigma=0.58$ ). Based on these  
 80 comparisons, we feel confident we can use this ensemble to evaluate ERCOT's forecasts.

81



82  
 83 **Figure 1.** Time series of seasonal maximum and minimum temperature over Texas (these are not population  
 84 weighted). (a) JJA maximum 1-day (solid line) temperature and 5-day (dashed line) temperature in ERA-5, and  
 85 green and yellow area each denotes the maximum and minimum ensemble member of 1-day and 5-day  
 86 temperature in CESM-LE. (b) Violin plot for distribution of 1-day and 5-day JJA maximum temperature in ERA-  
 87 5 and CESM-LE. Error bars represent the 95<sup>th</sup> and 5<sup>th</sup> percentile of the distribution, and the dots represent the  
 88 median of the distribution. (c, d) Same as (a, b), but for DJF minimum temperature.  
 89

90 3. The connection between electricity consumption and temperature in the historical record

91 Historical hourly electric power consumption is obtained from ERCOT for the period Jan. 1996-  
 92 Feb. 2021 ([http://www.ercot.com/gridinfo/load/load\\_hist/](http://www.ercot.com/gridinfo/load/load_hist/)). 2001 data are not available, so our  
 93 analysis excludes DJF 2001, JJA 2001, and DJF 2002. The first step is to regress population-

94 weighted daily average temperature against daily average power. We use a time-invariant  
95 population distribution averaged from 2000 to 2020 from CIESIN (2016) for the population  
96 weighting.

97

98 We perform the regression separately for each season of each year. Figs. 2a and 3a show a tight  
99 relationship between temperature and power usage in JJA and DJF for the first and last year of  
100 ERCOT's record — other years (not shown) show similarly tight relationships. This indicates that,  
101 within a season, variations in temperature are the primary controlling factor for power usage.  
102 Based on our examination of the data, we use a linear fit for JJA and a non-linear polynomial fit  
103 ( $P = C_0 + C_1 T + C_2 T^{1.75}$ ) for DJF. In Section S1 of the supplement, we discuss this in detail and  
104 show how our formulation works better than other potential choices.

105

106 From each year's fit, we calculate  $P_{ref}$  for that year, which is power usage at a reference  
107 temperature ( $T_{ref}$ ). We use a reference temperature equal to the median temperature for JJA  
108 ( $28.8^\circ\text{C}$ ) and DJF ( $10.9^\circ\text{C}$ ). The time series of  $P_{ref}$  is plotted in Figs. 2b and 3b; this can be thought  
109 of as the seasonal average power usage that would have occurred if the temperature were fixed  
110 at the reference temperature. The increase in  $P_{ref}$  over time is due to changes in non-climate  
111 factors, such as population. We then perform a linear fit to represent  $P_{ref}$  as a function of year  
112 ( $P_{ref}(y)$ ) (all of the fits can be found in Supplement Section S2).

113

114 We expect the coefficients from each year's temperature-power regressions (Fig. 2a and 3a) to  
115 be correlated with  $P_{ref}$ . For example, increases in population will change the slope of the power-

116 temperature relation because, as population increases, changes in temperature will drive larger  
117 changes in power usage. Figs. 2c, 3c, and 3d show that these coefficients are indeed correlated  
118 with  $P_{ref}$ .

119

120 Given this, we can model daily average power usage at as a function of year and daily-average  
121 temperature  $T$ . For JJA:

$$122 \quad P_{JJA}(y, T) = P_{ref}(y) + (S(y) \times (T - T_{ref})) \quad (1)$$

123 Where  $P_{JJA}(y, T)$  is the daily average power for a day in year  $y$  with a population-weighted, daily  
124 average temperature  $T$ .  $P_{ref}(y)$  is the value of  $P_{ref}$  during JJA in year  $y$ ,  $S(y)$  is the slope of the  
125 power-temperature regression in year  $y$ , and  $T_{ref}$  is the JJA reference temperature. Note that  $S$   
126 was plotted in Fig. 2c as a function of  $P_{ref}$ , but because  $P_{ref}$  is a function of year, we can also  
127 express  $S$  as a function of year  $y$ .


128

129 Our equation for DJF is similar to the JJA equation except that the power-temperature relation  
130 has higher order terms:

$$131 \quad P_{DJF}(y, T) = P_{ref}(y) + (C_1(y) \times (T - T_{ref})) + (C_2(y) \times (T - T_{ref})^{1.75}) \quad (2)$$


132 As with the JJA relation, the coefficients  $C_1$  and  $C_2$  correlate with  $P_{ref}$  (Figs. 3c and 3d), so we  
133 can also express them as functions of year. Also remember that DJF  $P_{ref}$  and  $T_{ref}$  are different  
134 from JJA  $P_{ref}$  and  $T_{ref}$ .

135



136  
 137 **Figure 2.** (a) Scatterplot of population-weighted daily average temperature and daily average power usage in  
 138 the first and last year of ERCOT's historical record. Red circle denotes the power at the reference temperature  
 139 ( $P_{ref}$ ). (b) Evolution of  $P_{ref}$  over time. The red dashed line is a linear trend. (c) Slope of the temperature-power  
 140 relation as a function of  $P_{ref}$ . Each point represents a value from a single year.  
 141

142  
 143



144  
 145 **Figure 3.** Same as Figure 2, but for DJF. Because we use a 1.75-D power-temperature fit in DJF, we have two  
 146 constants, and these are plotted in panels c and d.  
 147


148 4. Prediction of future electricity consumption

149 Using the methodology described in the last section, we can produce an estimate of daily average  
150 power usage. For comparison to ERCOT forecasts, we convert this to daily *maximum* power  
151 (hereafter DMP), the highest hourly power demand during the day, using a linear regression  
152 between daily maximum and daily average power usage developed from the historical data. The  
153 correlation between these quantities has R values of 0.99 and 0.98 in JJA and DJF and an RMS  
154 error of 1.0 and 1.1 GW, respectively.

155  
156 Plugging ERA5 temperatures into Eq. 1 and 2, we can reproduce the historical seasonal maximum  
157 power (the highest hourly power demand during the season, hereafter SMP) quite closely (Figs.  
158 4a and 4b), with RMS differences of 1.0 GW and 1.5 GW for JJA and DJF, respectively (2021 is  
159 excluded from the DJF calculation due to the blackout). This good agreement may be surprising  
160 because we left out of our model many factors that one might have anticipated would be  
161 important (e.g., weekday vs. weekend, number of hours of sunlight). We investigated many of  
162 these factors and found that none of them significantly improved our ability to reproduce the  
163 observations.

164  
165 We also have taken the CESM-LE temperatures and used Eq. 1 and 2 to estimate SMP for the  
166 1996-2021 period. The shaded regions show the range of power predicted by the ensemble and  
167 ERCOT's historical power demand falls comfortably within the ensemble's envelope. This result  
168 is consistent with the fact that observed temperatures over this period fall within the CESM-LE's  
169 range of predicted temperatures (Fig. 1).

170



171  
172  
173  
174  
175  
176

**Figure 4.** Time series of seasonal maximum hourly power usage (SMP). (a) JJA SMP for 1996-2020. Black solid line represents the historical ERCOT record, and black dashed line represent the historical power usage estimated by us using ERA5 temperatures. The grey area depicts the range of power usage estimated from the CESM-LE. (b) Same as (a), but for DJF 1997-2021.

## 177 5. Comparison of seasonal power demand

### 178 5a. Comparison of summer power demand

179 In order to evaluate ERCOT's seasonal 2021 summer resources assessment  
180 (<http://www.ercot.com/content/wcm/lists/219840/SARA-FinalSummer2021.xlsx>), we have  
181 calculated a probability distribution of SMP for JJA 2021 using temperatures from the CESM-LE  
182 from the period 2016-2025, but with 2021's  $P_{ref}$  (Fig. 5a).

183

184 ERCOT predicted a most likely SMP of 77 GW, in good agreement with the peak of our probability  
185 distribution. ERCOT also predicted an extreme peak-load scenario of 80 GW, which they derived  
186 assuming that the worst-case scenario is a repeat JJA 2011 temperatures. Note that ERCOT  
187 provides no probabilistic information with which to interpret their extreme scenarios. Is this a  
188 90%, 95%, 99%, etc. confidence interval? We calculate that there is a 17% chance of JJA 2021  
189 SMP exceeding 80 GW (Fig. 5a), suggesting that the use of historical temperatures may not be a  
190 good way to estimate of extreme demand.

191

192 ERCOT also estimated a best-case of 87 GW of power available to satisfy peak demand.  
193 Comparing this to Fig. 5a shows that the ERCOT grid is running with very little margin, with 5% of  
194 the summers in the CESM-LE having an SMP within 4.3 GW of ERCOT's estimate of best-case  
195 available power and 20% of summers within 7.1 GW. In such a situation, minor but unanticipated  
196 declines in available power, such as what happens when several power plants go offline for  
197 maintenance at once, puts the ERCOT grid at risk of being unable to satisfy power demand.

198

#### 199 5b. Comparison of winter power demand

200 We now evaluate ERCOT's seasonal resource assessment made right before the DJF 2021 season  
201 (<http://www.ercot.com/content/wcm/lists/197378/SARA-FinalWinter2020-2021.xlsx>). We do  
202 that by comparing it to a probability distribution of SMP for DJF 2021 that we calculated using  
203 temperatures in the CESM-LE between 2016 and 2025, but with 2021's  $P_{ref}$  (Fig. 5b). ERCOT's  
204 most-likely SMP is 57 GW, very close to the peak of our predicted distribution. ERCOT's extreme  
205 peak load scenario is 67 GW, calculated assuming that the worst case was that Texas would  
206 experience temperatures as cold as DJF 2011's, the most recent very cold Texas winter.

207

208 Like their summer estimates, this extreme peak load scenario is low — we estimate that there  
209 was an 19% chance that SMP would exceed this value. Reality provided support for this: 2021 DJF  
210 minimum daily average population-weighted temperatures were 3.4°C colder than 2011's, from  
211 which we estimate that peak demand was 82 GW — about 15 GW above ERCOT's worst-case  
212 prediction.

213

214 ERCOT communicated to us that their estimate of DMP during the 2021 winter storm was 76 GW  
215 (Jeff Billo, personal communication, 2021), 6 GW lower than our estimate. We do not know how  
216 ERCOT comes up with their number, but we assume that they are using some type of a piecewise-  
217 linear fit. Using our own version of a piecewise-linear fit, we find that maximum power demand  
218 during the 2021 winter storm was 74 GW, which is close to ERCOT's estimate. However, as shown  
219 in Section S1, piecewise-linear fits tend to underestimate power demand at very cold  
220 temperatures. Without more information about ERCOT's estimate, though, we cannot  
221 confidently identify the source of the disagreement.


222

223 This difference has important implications for how much margin the ERCOT grid has. ERCOT  
224 estimates that, in the best case, there was 83 GW of power available. If our estimate is correct,  
225 then the ERCOT grid had essentially no margin in DJF 2021, meaning that any loss of power, e.g.,  
226 due to lack of weatherization of energy infrastructure, meant that the ERCOT grid could not  
227 satisfy power demand.

228

229 More generally, Fig. 5b shows that the ERCOT grid also runs with very little margin in winter, just  
230 as it does in summer. For DJF 2021, we estimate that 5% of winters in the CESM-LE had an SMP  
231 within 7.9 GW of ERCOT's best-case estimate of available power and 10% and 20% of winters  
232 were within 12 and 17 GW, respectively. And 1.5% of the winters had SMP in 2021 DJF exceeding  
233 best-case available power, as approximately happened in 2021.

234



235  
 236 **Figure 5.** Probability distribution of seasonal hourly maximum power usage (SMP) in (a) JJA 2021 and (b) DJF  
 237 2021, predicted by the CESM-LE. Calculations use temperatures from 2016-2025 and  $P_{ref}$  for 2021. Grey and  
 238 black vertical lines represent the ERCOT’s seasonal forecast for extreme peak-load and best-case available  
 239 power.  
 240

241 **6. Conclusions**

242 One of ERCOT’s most important jobs is ensuring that there is sufficient power available to the  
 243 Texas electrical grid. In support of this objective, ERCOT makes seasonal assessments of future  
 244 power demand. However, ERCOT does not take climate change into account or use modern

245 climate forecasting tools to estimate climate variability when making these forecasts. Instead,  
246 they exclusively use the historical climate record.

247

248 In this paper, we describe an empirical methodology to estimate the impacts of climate change  
249 and weather variability on power demand. We then use output from an ensemble of climate  
250 model runs (the CESM-LE) to estimate the impact of climate change and variability on ERCOT's  
251 forecasts. We find that ERCOT's exclusive use of historical temperatures means that they  
252 underestimate the worst-case scenarios. We estimate a 17% and 19% chance that 2021 JJA and  
253 2021 DJF power demand would exceed ERCOT's extreme peak load scenarios, respectively. After  
254 the fact, we find that 2021 DJF maximum power demand exceeded ERCOT's extreme peak load  
255 scenario by 15 GW or 22%.

256

257 ERCOT disputes our estimate of peak demand during the 2021 DJF (82 GW) — they estimate  
258 demand was 76 GW. Resolution of this difference is important because it has implications for  
259 how much of a safety margin the ERCOT grid has, but ERCOT's model and underlying data are not  
260 publicly available so we are unable to identify the source of this disagreement. ERCOT should be  
261 transparent about their forecasts and should make their forecast model public so researchers  
262 can better evaluate their methodology.

263

264 In both summer and winter, we find that ERCOT's electricity grid has little spare capacity.  
265 According to ERCOT, best-case power available in 2021 is in the mid-80s GW. We find that power  
266 demand can frequently get approach that limit in both summer and winter. That means that

267 unforeseen problems that reduce supply even slightly below the best case can lead to the power  
268 grid being unable to satisfy power demand.

269  
270 Finally, we encourage ERCOT to make probabilistic forecasts of temperature using modern tools,  
271 like climate model ensembles. ERCOT's insistence on using historical weather observations  
272 means they are underestimating climate variability, leading to underestimates of the most  
273 extreme power demand forecast. ERCOT could easily do a better job in this regard — they just  
274 need to decide to do it.

275

#### 276 Acknowledgments

277 This work was supported by NSF grant AGS-1841308 to Texas A&M University. We thank Drs.  
278 John Nielsen-Gammon, James Doss-Gollin, Daniel Cohan, Jeffrey Billo, Calvin Opheim, and  
279 Yangyang Xu for the helpful discussions and comments. The authors declare that there is no  
280 conflict of interest.

281

#### 282 Data Availability Statement

283 Historical hourly power usage data from ERCOT can be publicly downloadable from the hourly  
284 load data archive provided by ERCOT ([http://www.ercot.com/gridinfo/load/load\\_hist/](http://www.ercot.com/gridinfo/load/load_hist/)). ERA-5  
285 reanalysis data are also publicly downloadable from the Climate Data Store  
286 (<https://cds.climate.copernicus.eu/#!/home>). Gridded population data (GPW v4) is available in  
287 NASA's Socioeconomic Data and Applications Center (SEDAC) archive  
288 (<https://sedac.ciesin.columbia.edu/data/collection/gpw-v4>).

289

290 **References**

- 291 Busby, J. W., and Coauthors, 2021: Cascading risks: Understanding the 2021 winter blackout in  
292 Texas. *Energy Research & Social Science*, **77**, 102106.
- 293 CIESIN, 2016: Gridded population of the world, version 4 (GPWv4): Population count. Palisades,  
294 NY: NASA socioeconomic data and applications center (SEDAC). *Center for International*  
295 *Earth Science Information Network (CIESIN) Columbia University*.
- 296 Doss-Gollin, J., D. J. Farnham, U. Lall, and V. Modi, 2021: How unprecedented was the February  
297 2021 Texas cold snap? *Environmental Research Letters*, **16**, 064056.
- 298 Frankenfield, J., 2021: Texas Seeks Relief as Winter Storm Damage Piles Up. *The New York Times*.
- 299 Hersbach, H., and Coauthors, 2020: The ERA5 global reanalysis. *Quarterly Journal of the Royal*  
300 *Meteorological Society*, **146**, 1999-2049.
- 301 Ivanova, I., 2021: Texas winter storm costs could top \$200 billion — more than hurricanes Harvey  
302 and Ike. *CBS News*.
- 303 Kay, J. E., and Coauthors, 2015: The Community Earth System Model (CESM) large ensemble  
304 project: A community resource for studying climate change in the presence of internal  
305 climate variability. *Bulletin of the American Meteorological Society*, **96**, 1333-1349.