

# Constructing statutory energy goal compliant wind and solar PV infrastructure pathways \*

Austin Thomas (corresponding author)

Rubenstein School of Environment and Natural Resources,

University of Vermont, Burlington, Vermont, USA 05405;

Gund Institute for Environment, Burlington, Vermont, USA 05405.

athoma20@uvm.edu

Pavan Racherla

Department of Electrical and Biomedical Engineering,

University of Vermont, Burlington, Vermont, USA 05405.

pracherl@uvm.edu

30 October 2019

---

\*Preprint submitted to *Renewable Energy* on 13 June 2019

## **Abstract**

Concerns over climate change have led governments around the world to establish a range of renewable, low-carbon energy goals. Plans for meeting these targets vary widely in their ambition, specificity, and time horizons. Wind and solar electricity generation will feature prominently in future energy systems that meet these renewable, low-carbon energy goals. Implementing large-scale wind and solar PV infrastructure configurations in a timely fashion will require cooperation between and among electric grid stakeholders and communities that host the infrastructure.

This paper presents methods for constructing a diverse range of wind and solar PV energy infrastructure pathways that meet statutory energy goals, measuring their land use impacts, and assessing their performance relative to electricity demand. A case study on the state of Vermont's statutory energy goals from its 2016 Comprehensive Energy Plan is presented as an example. While total wind and solar PV infrastructure requirements would increase several-fold, Vermont's statutory energy goals can be met while occupying less than 1% of the state's land area. Vermont electricity demand was most effectively met by balanced configurations of wind and solar PV similar to the state's present wind and solar PV resources, while 100% wind or 100% solar PV configurations were less effective.

## **Keywords**

Electric grid; decarbonization; statutory energy goals; wind turbines; solar PV panels; land use.

# Contents

- 1 Introduction** **4**
  
- 2 Methods and Data** **7**
  - 2.1 Weather data . . . . . 7
  - 2.2 Wind and solar PV power generation . . . . . 7
    - 2.2.1 Wind turbine modeling . . . . . 8
    - 2.2.2 Solar PV panel modeling . . . . . 9
    - 2.2.3 Conversion of capacity factors to power generation . . . . . 11
  - 2.3 Wind and solar PV land use . . . . . 11
  - 2.4 Modeling methods . . . . . 12
  
- 3 Vermont Case Study** **15**
  - 3.1 Current statutory energy goals . . . . . 15
  - 3.2 Wind and sunlight resources . . . . . 16
  - 3.3 Existing wind and solar PV infrastructure . . . . . 16
  - 3.4 Annual electricity imports, in-state generation, and consumption . . . . . 20
  - 3.5 Modeling assumptions and parameters . . . . . 21
  
- 4 Results** **24**
  - 4.1 Evaluating Vermont’s current wind and solar PV infrastructure . . . . . 25
  - 4.2 Land use impacts of Vermont SEG-compatible deployments . . . . . 28
  - 4.3 100% wind and 100% solar PV deployments . . . . . 35
  - 4.4 Assessing wind and solar PV deployments versus hourly load . . . . . 38
  
- 5 Discussion** **42**
  
- 6 Conclusion** **46**

# 1 Introduction

1 Climate change, driven by anthropogenic greenhouse gas emissions, has already increased global  
2 average surface temperatures by 1.0 °C [1]. The Intergovernmental Panel on Climate Change  
3 (IPCC) recently reiterated the need for “rapid and far-reaching transitions in energy, land,  
4 urban and infrastructure (including transport and buildings), and industrial systems” to limit  
5 global warming to 1.5 °C and avert the worst impacts of climate change [1]. Renewable,  
6 low-carbon energy sources, particularly wind and solar photovoltaic (PV) electricity generation,  
7 are increasingly being adopted worldwide both for environmental reasons and because of their  
8 increasingly competitive economic positions [2]. In response to these trends, local, regional,  
9 national, and international governments are establishing binding targets for renewable, low-carbon  
10 energy production, hereafter referred to as ‘statutory energy goals’ or SEGs [3] [4] [5]. Many SEGs  
11 focus on decarbonizing the electricity system and substituting fossil fuel energy consumption (e.g.  
12 transportation, heating, cooking, etc.) for electricity consumption. Achieving these SEGs through  
13 “rapid and far-reaching transitions” in the electricity system, among others, is crucial for averting  
14 the worst consequences of climate change.

15 Numerous studies of electricity systems powered by significant proportions of renewable,  
16 low-carbon energy sources have been conducted in recent years, covering topics including wind  
17 and solar PV generation reliability, electric grid stability and capacity constraints, and economic  
18 feasibility [6] [7] [8] [9] [10] [11] [12] [13]. These studies vary widely in their target wind and solar  
19 PV energy penetrations, the quantity and diversity of wind and solar PV infrastructure deployment  
20 scenarios tested, and the sophistication of their infrastructure siting methods. Relatively few  
21 studies explicitly consider the land use impacts of large-scale wind and solar PV infrastructure  
22 deployments and the influence of generation infrastructure siting choices on overall electricity  
23 system performance [14] [15] [16]. We contend that explicitly capturing these geospatial impacts  
24 of wind and solar PV electricity generation deployment is vital for understanding how high wind  
25 and solar PV-penetration electric grids will be implemented.

26 Large incumbent electricity generators like coal, natural gas, nuclear, and hydropower

27 generate large quantities of electricity on relatively small, widely separated parcels of land. This  
28 dynamic leads to significant land use and related environmental landscape impacts in the few  
29 areas that host the generators themselves, leaving most other areas of the landscape essentially  
30 unaffected. A future wind and solar PV powered grid will likely draw energy from electricity  
31 generation infrastructure that is distributed much more widely across the landscape than incumbent  
32 generators thanks to their reliance on prevailing weather conditions for electricity generation and  
33 their inherent modularity [17] [18]. In turn, the infrastructure siting processes that attend electricity  
34 system decarbonization driven by wind and solar PV will not only rise sharply in number but will  
35 also frequently trigger opposition from those who oppose the landscape disruption that wind and  
36 solar PV can cause [19] [20]. Existing land uses, land protections, and unsuitable terrain like  
37 waterways and steep slopes will also constrain wind and solar PV deployment. These phenomena  
38 represent significant hurdles to wind and solar PV growth and, if not recognized and dealt with,  
39 could greatly hinder the implementation of decarbonized electricity systems mandated by SEGs  
40 both in time and in scope. In North America, regional transmission organizations (RTOs) and  
41 independent system operators (ISOs) are charged with operating and modernizing the electric  
42 grid. RTOs and ISOs are under pressure to both accommodate new wind and solar PV generation  
43 capacity and maintain existing grid safety and energy provision reliability standards. If RTOs and  
44 ISOs can proactively plan for grid extensions and upgrades to accommodate high penetrations  
45 of wind and solar PV generation infrastructure, the chances of SEG achievement and continued  
46 grid reliability will increase dramatically. More granular infrastructure siting and landscape  
47 impact information can therefore enhance the efficacy of grid planning exercises and contribute  
48 significantly to grid decarbonization efforts.

49 This paper examines how different SEG-compatible wind and solar PV configurations  
50 compare on the basis of total generation infrastructure needs, land use requirements, and electricity  
51 demand satisfaction. The model used to build SEG-compatible wind and solar PV configurations  
52 relies on five years of high spatiotemporal resolution weather data for the continental United States  
53 (CONUS) to provide granular, high-quality electricity generation estimates. A case study for the

54 American state of Vermont and its SEGs is presented to illustrate how different wind and solar  
55 PV infrastructure ratios, siting patterns, and electricity demand levels drive wind and solar PV  
56 electricity generation infrastructure needs. By better defining what SEG-compatible wind and  
57 solar PV deployments look like and what impacts they have on the landscape, grid integration and  
58 planning studies can more readily capture the operational dynamics of highly wind and solar PV  
59 dependent electrical systems and reckon with the implementation challenges that will shape real-  
60 world, large-scale grid decarbonization. Section 2 of this paper describes the datasets and modeling  
61 methods used to produce SEG-compatible wind and solar PV infrastructure deployments. Section  
62 3 establishes the Vermont case study and section 4 contains the results of the case study scenarios.  
63 Section 5 contains a discussion of the case study findings and context for the enhancement and  
64 application of this study. Section 6 provides a concluding summary of this paper and suggested  
65 areas for proceeding work.

## 2 Methods and Data

66 The Renewable Energy Growth Scenario (REGS) model described here is an evolution of the  
67 model presented in [8]. Our model uses higher spatial resolution wind speed and sunlight data, two  
68 types of solar PV panels, and incorporates existing wind and solar PV generation infrastructure.  
69 Like [8], our model covers all of CONUS and allows for discrete modeling of wind and solar PV  
70 infrastructure by sub-region. Unlike [8], our model does not consider offshore wind turbine siting.

### 2.1 Weather data

71 [21] provides hourly irradiance and 80m elevation wind speed data from 2013 to 2017 for the  
72 CONUS, southern Canada, and northern Mexico on a 3km by 3km grid. The REGS model  
73 uses 43,800 hours of data spanning 0800 UTC 1 January 2013 to 0700 UTC 1 January 2018.  
74 29 February 2016 is omitted to simplify year-to-year comparisons and daylight saving time  
75 is ignored. Of the 43,800 hours possible in this date range, the JDS contains 35,192 hourly  
76 files for an availability rate of 80.3%. Gaps in the data were filled by systematically copying  
77 available data from equivalent hours in other years to ensure that climatological characteristics and  
78 sunlight availability are identical. The JDS was created using an experimental version of the High  
79 Resolution Rapid Refresh numerical weather prediction model. Biases in the wind and solar data  
80 are noted in sections 2.3, 2.4, and 5 of [21]. Wind speed biases in the JDS data are modest at  
81 approximately 0.5 to 1 m/s higher than observed wind speeds at a test site in Colorado. Sunlight  
82 biases are shown to be more variable across CONUS. In New England, where this paper's case  
83 study is located, sunlight biases in the JDS are as much as  $0.75 \text{ kWh m}^{-2} \text{ day}^{-1}$  sunnier than  
84 observations. See section 3.5 for further discussion.

### 2.2 Wind and solar PV power generation

85 Wind and solar PV electricity generation estimates are calculated using the JDS and a variety of  
86 assumptions about wind turbines and solar PV panels. This paper assumes that all installed wind

87 and solar PV infrastructure remains perfectly operational at all times and generates power purely as  
88 determined by the prevailing weather conditions. We do not attempt to account for infrastructure  
89 outages or performance degradation such as solar PV panel soiling, solar PV cell degradation,  
90 wind turbine equipment maintenance, wind turbine icing curtailment, electric grid connectivity  
91 interruptions, and so on. Additionally, all new wind and solar PV infrastructure placements are  
92 assumed to be accomplished with existing, commonly available turbines and PV panels.

### 2.2.1 Wind turbine modeling

93 All wind turbines (existing and new) are assumed to have hub heights of 80m, matching the  
94 elevation of wind speed data provided by the JDS. Hourly wind power capacity factors are  
95 calculated as a fraction of nameplate capacity using the following generic wind turbine power  
96 curve equation:

$$CF_{wind} = 0.52 * \tanh[(0.34 * W_{80m}) - 2.6] + 0.48 \quad (1)$$

97 for all wind speeds between 3 m/s and 15 m/s, where  $W_{80m}$  is the 80m wind speed from the JDS  
98 (see figure 1). Wind speeds between 15 m/s and 25 m/s result in  $CF_{wind} = 1$ ; wind speeds lower  
99 than 3 m/s or higher than 25 m/s result in  $CF_{wind} = 0$ . This wind turbine power curve approximates  
100 the wind turbine power curve presented in [22].




Figure 1: Wind turbine power generation curve



## 2.2.2 Solar PV panel modeling

101 Hourly solar PV panel capacity factors are calculated as a fraction of nameplate capacity using  
102 information about the solar PV panel mounting type, mounting location, and orientation relative  
103 to the Sun. All solar PV infrastructure is assumed to be either fixed-angle solar PV (FAPV) panels  
104 or two-axis tracking solar PV (TPV) panels. The orientation of a solar PV panel along with its  
105 latitude, longitude, and local time zone (i.e. hours offset from Greenwich Mean Time) are used  
106 to calculate  $\theta$ , the angle between the Sun's rays and the solar PV panel's normal vector at a given  
107 hour. All TPV panels are assumed to track the Sun perfectly and therefore have  $\theta = 0^\circ$  at all times.  
108  $\theta$  values for FAPV panels are calculated using [23]'s method as follows:

$$\theta = \arccos\left\{(A - B) \sin \delta + [C \sin \delta + (D + E) \cos \omega]\right\} \quad (2)$$

109 where:

$$A = \sin \phi \cos \beta \quad (3)$$

110

$$B = \cos \phi \sin \beta \cos \gamma \quad (4)$$

111

$$C = \sin \beta \sin \gamma \quad (5)$$

112

$$D = \cos \phi \cos \beta \quad (6)$$

113

$$E = \sin \phi \sin \beta \cos \gamma \quad (7)$$

114 and:

$$\beta = \text{PV panel tilt angle} \quad (8)$$

115

$$\gamma = \text{PV panel rotation angle} \quad (9)$$

116

$$\delta = 23.45 * \sin \left[ \frac{360 * (284 + JD)}{365} \right] \quad (10)$$

117

$$\phi = \text{latitude} \quad (11)$$

118

$$\psi = \text{longitude} \quad (12)$$

119

$$\omega = 15(TZ - 12) + [(15 * LT) - (15 * TZ)] + [(15 * TZ) - \psi] \quad (13)$$

120

$$JD = \text{Julian day} \quad (14)$$

121

$$LT = \text{Local Time (hours)} \quad (15)$$

122

$$TZ = \text{Time Zone (hours offset from Greenwich Mean Time)} \quad (16)$$

123 Sunlight data from the JDS are provided as sunlight fluxes normal to Earth's surface. Deriving the  
 124 capacity factor of an inclined solar PV panel of either type therefore requires the calculation of  
 125  $R_b$ , the ratio of sunlight exposure on an inclined surface to the sunlight exposure on a horizontal  
 126 surface. Using [24]'s method,  $R_b$  is calculated as follows:

$$R_b = \frac{\cos \theta}{\cos \theta_z} \quad (17)$$

127 where:

$$\cos \theta_z = \cos \phi \sin \delta + \cos \phi \cos \omega \cos \delta \quad (18)$$

128 For overnight hours,  $R_b$  is set to zero.  $R_b$  is capped at 4 to limit artificial overproduction of solar  
 129 power in hours very near sunrise and sunset.  $R_b$  is then used to calculate solar panel capacity  
 130 factors,  $CF_{PV}$ , as follows:

$$CF_{PV} = \begin{cases} S_{JDS} * R_b & S_{JDS} \leq S_{CS} \\ S_{CS} * R_b & S_{JDS} > S_{CS} \end{cases} \quad (19)$$

131 where  $S_{JDS}$  is the solar irradiance at the surface in  $W/m^2$  from the JDS and  $S_{CS}$  is the estimated  
 132 horizontal clear sky solar irradiance at the surface using [25]'s method:

$$S_{CS} = 1098 * \cos \theta_z * \exp \left\{ \frac{-0.057}{\cos \theta_z} \right\} \quad (20)$$

### 2.2.3 Conversion of capacity factors to power generation

133 Wind and solar PV power generation per hour per JDS grid box is calculated by multiplying  
134 the nameplate capacities of each type of generator with their respective capacity factor data.  
135 Wind turbines are assumed to generate alternating current (AC) power matching their nameplate  
136 capacities. Solar PV panels are assumed to produce direct current (DC) power at their nameplate  
137 capacities; AC power generation is determined by factoring in user-defined inverter losses.

138  $CF_{wind}$  and  $CF_{PV}$  are linearly interpolated on a minutely basis to reduce power generation  
139 errors. If  $CF_{wind}$  and  $CF_{PV}$  were used to calculate hourly generation directly, only the weather  
140 conditions at the start of the hour would determine generation for the entire hour. For example,  
141 if a given location experiences calm winds at the start of an hour and strong winds at the start  
142 of the next hour, the entire intervening hour would have no wind power generation. Similarly,  
143 hours in which the Sun rises would erroneously have no solar PV power generation for the entire  
144 hour and hours in which the Sun sets would erroneously generate solar PV power after sunset. By  
145 interpolating generation between hours on a minutely basis, the general trends of the wind and sun  
146 resources intra-hour are captured, though some variability is undoubtedly missing as compared  
147 to the real-world meteorological conditions. Capturing this variability would require higher time  
148 resolution data which is not yet available.

## 2.3 Wind and solar PV land use

149 The REGS model aggregates wind and solar PV infrastructure land use to 3km by 3km grid  
150 boxes matching those of the JDS. Existing wind and solar PV infrastructure, if provided, is first  
151 aggregated to the nearest grid box and then parameterized at a fixed rate of nameplate capacity  
152 per  $m^2$ . All subsequent wind and solar PV infrastructure is added in 60m by 60m (3600  $m^2$ )  
153 increments.

154 All FAPV infrastructure is assumed to occupy land at a rate of 186  $kW_{DC}$  per 60m by 60m  
155 plot (51.67  $W_{DC}$  per  $m^2$ ) and all TPV infrastructure is assumed to occupy land at a rate of 96  $kW_{DC}$   
156 per 60m by 60m plot (26.67  $W_{DC}$  per  $m^2$ ). FAPV land use intensity is drawn directly from [26],

157 while TPV use land intensity is slightly lower than the value reported in [26] based on estimates  
158 of existing TPV facilities in the state of Vermont. Rooftop FAPV installations are treated as if they  
159 are ground-mounted and therefore occupy land.

160 All wind turbines are assumed to occupy land at a rate of  $3,000 \text{ kW}_{AC}$  per 60m by 60m  
161 plot ( $83.33 \text{ W}_{AC}$  per  $\text{m}^2$ ). All new and existing wind turbines, regardless of nameplate capacity,  
162 are assumed to have an 80m hub height to simplify capacity factor calculations. To prevent wind  
163 turbine overcrowding<sup>1</sup>, total wind turbine capacity is capped at  $27 \text{ MW}_{AC}$  per grid box, equivalent  
164 to nine,  $3\text{MW}_{AC}$  wind turbines per grid box or  $3\text{MW}_{AC}$  per  $\text{km}^2$ . Additional direct land use impacts  
165 of wind turbines such as service roads, easements, electricity transformation and transmission  
166 infrastructure, service buildings, meteorological observation equipment, etc. are not included in  
167 this model. While these attendant secondary land use impacts are typically much larger than the  
168 footprint of a wind turbine itself, it is difficult to accurately and fairly parameterize these land use  
169 impacts given the variability in wind farm configurations [27].

## 2.4 Modeling methods

170 The REGS model constructs new wind and solar PV infrastructure configurations by using  
171 weighted random number selection to determine the infrastructure type, infrastructure siting  
172 method, and finally the location of the new wind turbine or solar PV panel array within the  
173 desired domain. The model is initialized with parameters indicating which grid boxes within  
174 CONUS are included in the test domain, how much land within each test domain grid box is  
175 restricted for development, where existing wind and solar PV infrastructure exists in the test  
176 domain, the desired ratio of new FAPV nameplate capacity to new TPV nameplate capacity to  
177 new wind turbine nameplate capacity, the desired infrastructure siting methodologies and their  
178 relative frequency, and the desired modeling goal (e.g. a specific amount of total wind and solar

---

<sup>1</sup>Wind turbines cannot be placed directly next to one another as solar PV panels can due to the inherent spacing required between wind turbines to maintain operational safety and downwind wake effects on neighboring wind turbines. This spacing is referred to in this work as *indirect land use*. The modeling restriction of 9 wind turbines per  $9\text{km}^2$  imposed here thus means that indirect land use is incurred at a rate of  $1/3 \text{ km}^2$  per  $\text{MW}_{AC}$  of wind turbine capacity.

179 PV nameplate capacity, land occupation, or TWh of annual electricity generation). Parameters  
180 that weight infrastructure type and infrastructure siting method to the user’s specifications are also  
181 included.

182         New wind and solar PV infrastructure placements are performed individually in an iterative  
183 process. Figure 2 provides a visual flowchart summary of the REGS model infrastructure siting  
184 process. First, infrastructure type is selected randomly based on the user-defined ratio of desired  
185 new infrastructure types. As the model runs, infrastructure types that are over-represented  
186 as a percentage of newly installed capacity in the model are excluded from selection. As  
187 subsequent infrastructure selections are made, the relative proportion of a particular infrastructure  
188 type recedes towards the desired ratio until ultimately it is under-represented and is made  
189 eligible for selection. This “rubber-banding” effect prevents the final infrastructure ratio from  
190 diverging substantially from the user’s desired infrastructure ratio. In cases where the model  
191 is tasked to maximize electricity generation over other factors, this model behavior also gives  
192 each infrastructure type a proportionally fair chance to occupy the highest average electricity  
193 generation locations, particularly when grid boxes have both a high quality wind and sunlight  
194 resource. Once the infrastructure type is selected, one of three infrastructure siting methods is  
195 chosen. New infrastructure can be placed to maximize electricity generation, to occupy grid boxes  
196 where other infrastructure of its own type is already located (hereafter referred to as *clustering*),  
197 and randomly. Finally, the model randomly selects the grid box which will receive the new  
198 infrastructure placement, subject to existing direct and indirect land use occupation, land use  
199 restrictions, and user-defined siting preferences. The probability of a given grid box receiving  
200 the new infrastructure placement depends on the siting criteria selected and how much bias is  
201 given towards high quality grid boxes versus low quality grid boxes. If a new wind turbine is  
202 being placed to maximize generation, for example, the model scales the estimated annual TWh  
203 generation of each grid box in the domain by a user-defined exponent. Next, the cumulative sum  
204 of these values is calculated and site selection probabilities for each grid box are assigned based  
205 on the grid box’s share of the cumulative sum. Finally, a random number draw determines which

206 eligible grid box receives the new wind turbine or solar PV panel array. The additional land use  
207 incurred and electricity generated by the new infrastructure is added to the existing wind and solar  
208 PV infrastructure, thus completing the cycle. If the most recent infrastructure placement does  
209 not break the target modeling threshold, the model begins the infrastructure placement process  
210 anew. Otherwise, the model reports out the locations and amounts of new wind and solar PV  
211 infrastructure deployed by the model.




Figure 2: REGS model flowchart

### 3 Vermont Case Study

212 The remainder of this paper uses the REGS model to perform a case study of the state of Vermont  
213 and its SEGs. This case study aims to illustrate how different wind and solar PV infrastructure  
214 choices can be used to meet SEGs, how different wind and solar PV siting strategies can influence  
215 electricity generation returns, and the land use consequences of these choices.

#### 3.1 Current statutory energy goals

216 Vermont has established several SEGs that govern electricity, heating/cooling, transportation, and  
217 other energy uses. These SEGs are catalogued in the state's 2016 Comprehensive Energy Plan  
218 (CEP) [4]. The 2016 CEP establishes goals of meeting 90% of Vermont's total energy needs with  
219 renewable energy sources by 2050, with intermediate goals of 40% by 2035 and 25% by 2025.  
220 Additional sector-specific goals relevant to the present study include meeting 67% of electricity  
221 demand by 2025 and 75% of electricity demand by 2032 with renewable energy sources, meeting  
222 25% of total energy demand with in-state renewable energy resources by 2025, and meeting 10% of  
223 electricity demand from distributed generation resources (e.g. rooftop solar PV, small-scale wind  
224 turbines, waste-to-energy systems, etc.) by 2032. Though this case study focuses on SEGs related  
225 to the electricity sector, it is likely that some fraction of presently non-electric energy consumption  
226 in Vermont and elsewhere will be electrified even under business-as-usual conditions. This study  
227 will therefore consider, in general terms, the potential increase in electricity demand in Vermont  
228 from increased electrification of non-electric energy demands. More generally, the 2016 CEP  
229 reiterates the state's long-term goal of limiting Vermont's overall greenhouse gas emissions in  
230 2050 to 25% of the state's 1990 greenhouse gas emissions. Meeting this goal will likely require  
231 significant electrification of presently non-electric energy demands and, consequently, significant  
232 growth in the generation of low-carbon or carbonless electricity to meet these new energy demands.

## 3.2 Wind and sunlight resources

233 The state of Vermont is relatively small compared to other American states in terms of land area,  
234 population, and total energy consumption [28]. Significant portions of Vermont are covered by  
235 lakes, wetlands, and a variety of protected lands managed by local, state, and federal agencies. The  
236 majority of Vermont's protected lands lie along the Green Mountains and adjacent foothills which  
237 run north-south through the center of Vermont (see figures 3A and 3B). The Green Mountains also  
238 significantly influence Vermont's wind and sunlight resource quality. The western slopes and peaks  
239 of the Green Mountains are home to Vermont's highest mean wind speeds as indicated by the dark  
240 green stripe in eastern Chittenden, Addison, Rutland, and Bennington counties (see figure 3C). The  
241 lowest mean wind speeds in Vermont are found in the valleys immediately east (climatologically  
242 downwind) of the Green Mountains in Lamoille, Washington, and western Orange Counties as  
243 well as the broader Connecticut River valley along the eastern edge of Vermont. In figure 3D, the  
244 impact of the climatological rain shadow induced by the Green Mountains can be clearly seen.  
245 Areas east of the Green Mountains, particularly Windsor and Windham counties, are 10 to 30%  
246 sunnier than western Vermont. Mean solar irradiance is much less variable than mean wind speeds  
247 across the Vermont, however, with the windiest locations in Vermont having almost triple the mean  
248 wind speed of the calmest locations. Wind turbine electricity generation potential is therefore much  
249 more sensitive to siting than solar PV generation in Vermont.

## 3.3 Existing wind and solar PV infrastructure

250 At the beginning of 2018, Vermont had approximately  $149 \text{ MW}_{\text{AC}}$  of wind turbines,  $168 \text{ MW}_{\text{DC}}$   
251 of FAPV, and  $19 \text{ MW}_{\text{DC}}$  of TPV [32] (see figure 4). The ratio of FAPV to TPV to wind turbine  
252 nameplate capacity in Vermont is thus  $444 \text{ kW}_{\text{AC}}$  to  $56 \text{ kW}_{\text{DC}}$  to  $500 \text{ kW}_{\text{DC}}$  per MW of total  
253 nameplate capacity. Rooftop FAPV capacity represents  $58 \text{ MW}_{\text{DC}}$  (34.4%) of the total FAPV  
254 capacity. Vermont's five active wind farms are located on or near mountain peaks, far from large  
255 populations centers.

256 Vermont covers a total of  $25,146 \text{ km}^2$ , of which  $18,305 \text{ km}^2$  [72.8%] is not covered






Figure 3: (A) Elevation above mean sea level, county names, and county boundaries [29]  
 (B) Lakes, wetlands, and protected lands [30] [31]  
 (C) Mean wind speed at wind turbine hub height [21]  
 (D) Mean daily solar irradiance at Earth's surface [21].

257 by surface water, wetlands, conservation and wildlife protections, or is otherwise restricted  
 258 from development. Existing wind and solar PV infrastructure covers approximately 4.14 km<sup>2</sup>  
 259 [0.017%] of Vermont<sup>2</sup>. Much of Vermont’s solar PV capacity is located in and around the state’s  
 260 largest towns and cities, such as Burlington (Chittenden County), Middlebury (Addison County),  
 261 Montpelier (Washington County), and Brattleboro (Windham County). Table 1 summarizes the  
 262 distribution of solar PV generation capacity across Vermont’s 14 counties and the size of each  
 263 county. All Vermont counties have at least some installed solar PV capacity. Chittenden and  
 264 Addison counties alone provide over a third of Vermont’s solar PV capacity despite having only  
 265 15% of Vermont’s land area.

	Total Area (sq. km)	Total Area (% of VT)	Available Area (sq. km)	Available Area (% of VT)	Solar PV Capacity (MW <sub>DC</sub> )	Solar PV Capacity (% of VT)
Addison	2,114	8.41	1,276	6.97	31.055	16.55
Bennington	1,766	7.02	971	5.30	8.011	4.27
Caledonia	1,722	6.85	1,462	7.99	5.552	2.96
Chittenden	1,623	6.45	1,121	6.13	40.378	21.53
Essex	1,766	7.02	857	4.68	1.193	0.64
Franklin	1,817	7.22	1,374	7.51	14.056	7.50
Grand Isle	510	2.03	177	0.97	2.680	1.43
Lamoille	1,214	4.83	902	4.93	6.152	3.28
Orange	1,809	7.19	1,653	9.03	12.712	6.78
Orleans	1,889	7.51	1,547	8.45	7.075	3.77
Rutland	2,466	9.81	1,759	9.61	19.922	10.62
Washington	1,821	7.24	1,451	7.92	13.241	7.06
Windham	2,080	8.27	1,669	9.12	9.395	5.01
Windsor	2,548	10.13	2,086	11.39	16.102	8.59
TOTAL	25,146		18,305		187.504	

Table 1: Vermont land area and January 2018 solar PV infrastructure

<sup>2</sup>4.14 km<sup>2</sup> of land use assumes rooftop solar PV panels are instead ground-mounted as laid out in section 2.3. This and other land use estimates made in this paper therefore represent a likely ‘worst-case scenario’ upper bound or overestimate of actual solar PV land use.




Figure 4: Estimated installed wind turbines and solar PV panels in Vermont as of January 2018. Wind turbines are marked individually and solar PV panels are grouped by installation and then marked. For the sake of map readability, dot size does not reflect installed generation capacity.

### 3.4 Annual electricity imports, in-state generation, and consumption

266 Vermont relies on a range of in-state and out-of-state electricity generation capacity to meet its  
267 electricity needs. Of the 5.522 TWh of electricity sales made in Vermont in 2018, 1.392 TWh  
268 (25.2%) were met by in-state hydroelectric generation, 0.421 TWh (7.6%) were met by in-state  
269 biomass generation, 0.393 TWh (7.1%) were met by in-state wind generation, and 0.273 TWh  
270 (4.9%) were met by in-state solar PV generation, resulting in a total of 2.479 TWh (44.9%)  
271 of electricity demand being met by renewable electricity generation sources<sup>3</sup> [33]. A further  
272 approximately 1.300 TWh (23.5%) of hydroelectric power is supplied to Vermont by Québec per  
273 year [4]. The remaining 1.743 TWh (31.6%) of electricity demand per year is met by a range of  
274 conventional generation sources (primarily coal, natural gas, hydroelectric, and nuclear) located  
275 across New England. Total energy consumption in Vermont in 2016 was 128.7 trillion British  
276 Thermal Units (BTU), equivalent to 37.718 TWh of electrical energy [34]. Assuming a similar  
277 amount of total energy was consumed in 2018, electricity therefore represented just 14.64% of  
278 Vermont’s total energy demand in 2018 (not including losses and inefficiencies in electricity  
279 generation, transmission, and distribution), resulting in wind and solar PV generation resources  
280 within Vermont meeting only 1.76% of Vermont’s total energy demand in 2018.

281 Total annual electricity demand is only one measure of electricity system performance,  
282 however; the hour-by-hour fluctuations in electricity demand determine which generators (and  
283 therefore which fuels) are used by grid operators to meet electricity demand. Figure 5 shows  
284 mean hourly Vermont electricity demand (hereafter referred to as *load*) for the years 2013-2017,  
285 corresponding to each hour of weather data from the JDS [35]. Vermont load exhibits diurnal and  
286 seasonal patterns in-line with other developed societies in temperate climates. Load at any given  
287 time is influenced by the prevailing weather conditions in a given region (particularly temperature),  
288 time of day, day of the week, holidays, and normal electricity consumer behaviors. Grid operators  
289 obey a “supply follows demand” paradigm which means they must ramp generators up and down as

---

<sup>3</sup>The REGS model estimates that Vermont’s January 2018 wind and solar PV infrastructure would have generated an average of 0.366 TWh of wind power per year and 0.275 TWh of solar PV power per year when parameterized as discussed in sections 2.2.1, 2.2.2, and 3.5.

290 load increases and decreases. The sharp load increase between 4AM and 7AM and corresponding  
 291 load decrease between 6PM and 10PM are particularly challenging for grid operators to manage.  
 292 As controllable generation sources are replaced by intermittent generators like wind and solar PV,  
 293 it will be increasingly difficult for grid operators to meet load reliably and safely. Measuring  
 294 the effectiveness with which wind and solar PV meet load in the absence of large-scale energy  
 295 storage device deployment or coordinated wind and solar PV generation curtailment is therefore  
 296 an important metric to consider when analyzing large-scale wind and solar PV infrastructure  
 297 deployments.




Figure 5: Average daily Vermont electricity demand for 2013 through 2017 [35]. Winter includes December, January, and February; spring includes March, April, and May; summer includes June, July, and August; autumn includes September, October, and November.

### 3.5 Modeling assumptions and parameters

298 This paper applies a number of modeling assumptions and parameterizations to the REGS in order  
 299 to minimize the operational differences of real-world wind and solar PV infrastructure deployments  
 300 to simulated configurations. The assumptions and parameters listed here are user-controllable

301 options within the REGS model, rather than inherent modeling choices such as the assumption of  
302 an 80m turbine hub height for all existing and new wind turbines.

303 • Reduction of sunlight and wind biases (see section 2.1). The JDS carries biases in both wind  
304 and sunlight which must be counter-balanced in order to produce more realistic electricity  
305 generation data. For the below case study, wind speeds are unmodified while irradiance is  
306 reduced by 15%. While wind speeds in the JDS were verified against a sample wind turbine  
307 in the state of Colorado, it is not clear if the same biases are present in New England generally  
308 or Vermont specifically. Regardless, the modeled average annual wind power generation  
309 for Vermont's 149 MW<sub>AC</sub> of wind turbines only slightly underestimates the actual reported  
310 Vermont wind power generation from 2018 (0.366 TWh versus 0.393 TWh, respectively).  
311 We therefore elect to leave the JDS' wind speed data unchanged. Irradiance data were  
312 reduced by 15% to offset the sunny bias present in the northeastern CONUS as depicted  
313 in figure 15 of [21].

314 • FAPV panel orientation. Solar PV panels are mounted at a wide variety of angles relative to  
315 the Sun and for a wide variety of reasons. While [32] provides basic information about  
316 the PV panel mounting type and mobility, the exact orientation of FAPV panels is not  
317 provided. In this case study, all FAPV panels are assumed to remain in one position year-  
318 round. Furthermore, all FAPV panels are assumed to be oriented equatorward (i.e. due  
319 south for all locations in the CONUS) and inclined at an angle of one half of local latitude.  
320 This orientation represents a more optimal panel orientation for summer solar PV generation  
321 potential and a balanced solar PV generation potential with respect to time of day [36].

322 • Power conversion losses. Both wind turbines and solar PV panels produce power which  
323 cannot be transmitted directly to the grid. Wind turbines typically generate power in AC  
324 but at a grid-asynchronous frequency. Solar PV panels produce DC power which can be  
325 used directly for local consumption (e.g. charging a battery or an electric vehicle) but must  
326 be converted to AC for transmission to the grid. In both cases, the power losses from the

327 necessary conversion processes are small; for simplicity, this case study assumes they are  
328 zero. Inverters are typically built into wind turbines themselves and are therefore sized  
329 to match their nameplate capacities. Again, this case study assumes this to be the case  
330 and leaves wind turbine power generation unchanged. Solar PV panel arrays typically  
331 share inverters across panels given the small individual nameplate capacity of individual  
332 panels. The economics of inverters means that higher capacity and higher efficiency inverters  
333 are more expensive than lower capacity and lower efficiency inverters. Since solar PV  
334 panel arrays will rarely achieve their full rated power generation capacity, it is generally  
335 uneconomical to pair solar PV panel arrays with inverters of matching capacities [37]. This  
336 case study therefore applies a 20% reduction in AC solar PV power generation relative to  
337 DC solar PV power generation to account for this inverter sizing discrepancy.

## 4 Results

338 To illustrate how different SEG-compatible wind and solar PV configurations compare on total  
339 infrastructure needs, land use, and load satisfaction, a range of potential wind and solar PV  
340 configurations for the state of Vermont are developed and examined. First, we examine how  
341 Vermont's existing wind and solar PV infrastructure performs as compared to hypothetical  
342 alternative arrangements of the same amounts of infrastructure. Second, we construct and analyze  
343 a range of expanded wind and solar PV infrastructure deployments that satisfy four Vermont SEGs  
344 using ratios of wind and solar PV infrastructure that match the initial infrastructure deployment.  
345 Third, we construct SEG-compliant infrastructure configurations that extend the initial wind and  
346 solar PV configuration solely using wind turbines or solely using solar PV panels. Fourth, each  
347 of the above wind and solar PV infrastructure configurations is tested against real-world Vermont  
348 load data to assess its ability to meet load. These results, in combination, provide insights on the  
349 amounts of wind and solar PV infrastructure needed to satisfy SEGs and the general strengths  
350 and weaknesses of each as a potential pathway for renewable, low-carbon electricity provision in  
351 Vermont.

352 A combination of four SEGs, as described in [4], form the basis for future wind and solar  
353 PV infrastructure deployment targets analyzed in this paper. The four SEGs chosen for testing are:

- 354 • Meet 100% of Vermont's electricity demand with renewable energy sources
- 355 • Meet 25% of Vermont's total energy demand with renewable energy sources
- 356 • Meet 25% of Vermont's total energy demand with in-state renewable energy sources
- 357 • Meet 40% of Vermont's total energy demand with renewable energy sources

358 These targets correspond to approximately 5.5 TWh, 9.4 TWh, 9.4 TWh, and 15.1 TWh of  
359 electricity per year, respectively [34]. In order to set appropriate target levels of total new wind  
360 and solar PV electricity generation needed, existing renewable electricity generation detailed above  
361 (not including existing wind and solar PV generation) must be deducted. All 1.8 TWh of annual



362 Vermont renewable electricity generation not derived from wind or solar PV plus the 1.3 TWh of  
363 hydroelectricity imported annually from Québec can be deducted from the first, second, and fourth  
364 SEG targets. Only the approximately 1.8 TWh of in-state annual Vermont renewable electricity can  
365 be deducted from the third SEG target. The final annual wind and solar PV electricity generation  
366 targets to be examined are therefore 2.4 TWh, 6.3 TWh, 7.6 TWh, and 12.0 TWh. These scenarios  
367 represent approximate increases of wind and solar PV electricity generation in Vermont relative to  
368 January 2018 by a factor of 3.5, 9.5, 11.5, and 18, respectively. The nameplate capacity, land use,  
369 and electricity generation data reported in the proceeding tables and figures reflect the mean and  
370 standard deviation of 50 identically parameterized model runs. Differences between model runs  
371 arise from variations in random number selections that determine infrastructure type selection and  
372 site selection as discussed in section 2.4. Figures that depict wind and/or solar PV infrastructure  
373 deployments show only one representative result of the 50 total iterations.

#### **4.1 Evaluating Vermont’s current wind and solar PV infrastructure**

374 As a first step towards building SEG-compatible wind and solar PV infrastructure configurations,  
375 we examine the electricity generation performance of Vermont’s existing wind and solar PV  
376 infrastructure relative to two hypothetical infrastructure redeployments. The first alternative siting  
377 method strongly biases infrastructure placements of both types towards high annual electricity  
378 generation locations within the domain. This siting strategy, referred to hereafter as ‘maximum  
379 generation’, does not involve any optimization methodologies. The second alternative siting  
380 method is a simple random placement scheme and is referred to as such hereafter. This siting  
381 scheme acts as a control scenario for comparison against other siting methods and to the existing  
382 Vermont wind and solar PV configuration.

383 Figure 6 depicts example deployments of wind and solar PV under each alternative siting  
384 scheme relative to the status quo deployment. As expected, wind turbines are located along  
385 the spine of the Green Mountains in central Vermont under the maximum generation scenario.  
386 Solar PV panels are predominantly located in southern and eastern Vermont, matching the

387 state's strongest sunlight resource areas east of the Green Mountains. Both of the maximum  
388 generation scenario configurations differ sharply from the actual deployment of wind and solar  
389 PV infrastructure in Vermont. Most of Vermont's existing wind turbines, while sited on locally  
390 high terrain, do not capture the state's peak mean wind speeds. Likewise, much of Vermont's best  
391 solar resource is only partially utilized at best by the present solar PV panel deployment. As is  
392 discussed in later sections of this paper, maximizing generation output is but one of many criteria  
393 that prospective developers must consider when selecting a plot of land for wind and solar PV  
394 energy infrastructure installation. Random placement of both wind turbines and solar PV panels  
395 creates infrastructure deployments that resemble neither the actual deployment nor the maximum  
396 generation scenario.




Figure 6: Actual and hypothetical alternative Vermont wind and solar PV infrastructure arrangements

397 Table 2 shows the corresponding mean annual electricity generation performance of the  
 398 two alternative wind and solar PV infrastructure siting methods and of the initial Vermont wind  
 399 and solar PV infrastructure configuration. As expected, the maximum generation siting methods  
 400 produce infrastructure configurations that outperform Vermont’s actual configuration. Mean  
 401 annual solar power production is approximately 6% higher in the maximum generation scenario  
 402 as compared to the initial Vermont configuration while wind power generation nearly doubles.  
 403 The random placement scenario also yields slight improvements in both wind and solar PV mean  
 404 annual generation as compared to the initial Vermont configuration, though the difference between  
 405 the means (0.011) is smaller than the standard deviation of the random placement mean annual  
 406 electricity generation (0.016).

	Max. generation	Random placement	Initial config.
Wind	0.727* ± 0.002	0.373* ± 0.016	0.366
FAPV	0.248 ± 0	0.238 ± 0	0.235
TPV	0.042 ± 0	0.040 ± 0	0.039
TOTAL	1.017 ± 0.002	0.651 ± 0.016	0.640

Table 2: Mean annual electricity generation (TWh) from hypothetical alternative Vermont wind and solar PV infrastructure arrangements. NOTE: For modeling simplicity, 150 MW<sub>AC</sub> of wind turbine capacity (fifty 3 MW<sub>AC</sub> wind turbines) were sited in the maximum generation and random placement scenarios. This puts the ‘maximum generation’ scenario and ‘random placement’ scenario at a 1 MW<sub>AC</sub> advantage against Vermont’s initial wind turbine nameplate capacity.

## 4.2 Land use impacts of Vermont SEG-compatible deployments

407 The rest of section 4 presents modeled expansions of Vermont wind and solar PV infrastructure  
 408 using three siting methods. The first two siting methods used are the maximum generation and  
 409 random placement methods described above; the third siting method used is named ‘clustering’.  
 410 The clustering siting method weights each grid box according to how much land is already  
 411 occupied by a given wind or solar PV infrastructure type both within the grid box and and in  
 412 neighboring grid boxes. Only infrastructure-type land use in adjacent, cardinal direction grid

413 boxes is included in the weighting calculation and adjacent infrastructure-type land use is weighted  
414 at 50% as compared to the grid box's own infrastructure-type land use. The clustering siting  
415 method represents an approximate 'business as usual' wind and solar PV growth approach in which  
416 regions that currently host wind and/or solar PV infrastructure will receive more of it and areas that  
417 currently do not host wind and/or solar PV infrastructure will rarely, if ever, receive more. Siting  
418 of new wind and solar PV infrastructure under the clustering siting method, as with the other  
419 two siting methods, adheres to land use protections and competition for land availability among  
420 infrastructure types.

421 A total of twelve scenarios were generated using the REGS model, one for every  
422 combination of one of three siting methods and one of four Vermont SEGs as outlined at the start of  
423 section 4. Figures 7 and 8 show the deployment patterns of new wind and solar PV infrastructure  
424 for eight of the twelve scenarios. For brevity, the random placement scenarios are not depicted.  
425 Infrastructure siting patterns persist between the hypothetical maximum generation wind and solar  
426 PV configurations from the previous section and the expanded SEG-compatible deployments  
427 shown here. New wind turbines are located almost exclusively along the spine of the Green  
428 Mountains (figures 7A through D) to harness the Vermont's peak mean wind speeds and solar  
429 PV panels are predominantly located in Windsor and Windham counties (figures 8A through D)  
430 in line with Vermont's peak mean irradiance values. As annual electricity generation targets rise,  
431 wind turbines steadily saturate the best wind energy resource locations along the Green Mountains  
432 and begin to spread to Essex County in northeastern Vermont (figure 8D). Clustering-driven siting  
433 for wind (figures 7E through H) and solar PV (figures 8E through H) largely follow the spatial  
434 pattern set by Vermont's initial wind and solar PV infrastructure configuration. Wind turbine siting  
435 in these scenarios results in large, localized deployments surrounding the four existing clusters  
436 of wind turbines that grow steadily as electricity generation targets rise. New solar PV panel  
437 installations are much more diffuse throughout Vermont thanks to the state's initial solar PV panel  
438 distribution. A few individual grid boxes in Chittenden and Rutland counties exceed  $MW_{AC}$  of  
439 solar PV panel nameplate capacity and  $0.5 \text{ km}^2$  of total solar PV land use (figure 8H).




Figure 7: Total modeled Vermont wind turbine infrastructure growth under maximum generation and clustering siting methods




Figure 8: Total modeled Vermont solar PV panel infrastructure growth under maximum generation and clustering siting methods

440 Figures 9 reveals the mean wind and solar PV infrastructure requirements to meet each  
441 SEG. As expected, maximum generation siting achieved the SEG using the least amount of  
442 infrastructure across all four SEGs. As little as 0.92 GW<sub>AC</sub> of wind and solar PV infrastructure,  
443 including the 0.34 GW<sub>AC</sub> of infrastructure already installed, is sufficient to meet the first SEG  
444 of meeting 100% of Vermont's annual electricity needs through renewable energy resources. In  
445 contrast, both the random placement and clustering siting methods require over 1.2 GW<sub>AC</sub> of  
446 total wind and solar PV infrastructure. This approximately 35% jump in total infrastructure  
447 requirements between the maximum generation and the random placement/clustering siting  
448 method grows to over 44% for the three higher SEG thresholds. The disparity is such that a  
449 nearly equivalent amount of wind and solar PV infrastructure (approximately 4.3 GW<sub>AC</sub>, or more  
450 than ten-fold the amount of existing wind and solar PV infrastructure in Vermont presently) could  
451 either be used to generate 7.6 TWh of electricity per year under a random siting regime or nearly  
452 12.0 TWh of electricity per year when sited to maximize generation. Clustering siting scenarios  
453 only marginally outperform random placement scenarios across the four SEG thresholds, largely  
454 due to the placement of existing wind turbines in sub-peak wind resource regions.

455 Figure 10 shows the corresponding mean land area needed to accommodate each SEG-  
456 compatible infrastructure deployment. Land use requirements scale linearly with nameplate  
457 capacity because of the fixed land use per unit nameplate capacity and fixed FAPV to TPV to  
458 wind turbine capacity parameterizations. As little as 11 km<sup>2</sup> of direct land use is needed to  
459 accommodate a SEG-compatible 2.5 TWh/yr infrastructure configuration, which represents less  
460 than 0.1% of Vermont's total eligible land area. The most aggressive SEG target and largest land  
461 footprint infrastructure deployment combination, 12 TWh/yr achieved through random placement,  
462 requires only 77 km<sup>2</sup> [0.42%] of Vermont's eligible land. The equivalent maximum generation  
463 siting scenario only requires 53 km<sup>2</sup> [0.29%] of Vermont's eligible land.

464 Of the three infrastructure types modeled, wind turbines directly occupy far less land per  
465 unit of nameplate generation capacity as compared to FAPV and TPV panels. Across all twelve  
466 test scenarios, wind turbines represent 44.4% of the total nameplate generation capacity and at






Figure 9: Nameplate capacities of SEG-compatible wind and solar PV infrastructure deployments. G: maximum generation siting; R: random placement; C: clustering.

467 least 57% of the mean annual electricity generation but only 4.3% of the total infrastructure land  
 468 use footprint. In Vermont’s case, this makes wind turbines a superior choice relative to solar PV  
 469 panels of either type for maximizing annual electricity generation returns and minimizing land  
 470 use. This does not mean, however, that wind energy is without its landscape impacts; this topic is  
 471 revisited in depth in the proceeding discussion section. Furthermore, the relative strength of the  
 472 wind and sunlight resources in a particular region will strongly influence the advantages of wind  
 473 turbines to solar PV panels in electricity generation per unit land. Finally, the abundance or scarcity  
 474 of a region’s highest quality wind and sunlight resources will modulate how advantageous one




Figure 10: Land use requirements of SEG-compatible wind and solar PV infrastructure deployments. G: maximum generation siting; R: random placement; C: clustering.

475 infrastructure type is over another as total electricity generation targets increase. In the Vermont  
 476 case, the state's highest quality wind and sunlight resources are not significantly exhausted in  
 477 meeting the four SEGs tested due to the state's relatively low population density (reducing the  
 478 amount of infrastructure and therefore land needed to meet SEGs) and the proportionally large  
 479 areas of the state that have the highest mean wind speeds and sunlight exposure. Further comments  
 480 on the specificity of this case study's findings to Vermont can be found in the proceeding discussion  
 481 section.

### 4.3 100% wind and 100% solar PV deployments

482 We now examine two alternative infrastructure growth ratios under the same siting strategies to  
483 capture a more complete range of potential SEG-compatible wind and solar PV infrastructure  
484 deployment pathways. A wind-only or solar PV-only infrastructure deployment would be the only  
485 viable paths to achieving a SEG-compatible wind and solar PV-powered electricity system under  
486 a strict statewide constraint on development of one or the other infrastructure type. Examples of  
487 these constraints could include severe disruption of wind turbine or solar PV panel manufacturing,  
488 a legislative moratorium on further wind turbine or solar PV panel installation, and a grid operator-  
489 imposed moratorium on intermittent electricity generator interconnections.

490 Figure 11 shows how wind-only and solar PV-only infrastructure additions would satisfy  
491 Vermont's 12.0 TWh/year SEG under the maximum generation, random placement, and clustering  
492 siting methods. The spatial patterns of new infrastructure siting in these scenarios are consistent  
493 with those found previous scenarios. In figures 11B, 11D, and 11E, almost all of Vermont  
494 receives some new infrastructure except for grid boxes that fall entirely within protected parcels  
495 of land. Wind turbine clustering, as seen in figure 11C, shows that areas in Caledonia, Orleans,  
496 Windham, and Franklin counties that are as much as 24 kilometers away from existing wind turbine  
497 installations at present now have substantial wind turbine infrastructure installations. Though the  
498 total amount of land occupied by these high penetration scenarios on a statewide and gridbox  
499 by gridbox basis is relatively low, it is clear that large-scale wind turbine and solar PV panel  
500 deployments will impact Vermonters and Vermont landscapes in every county and almost every  
501 community in the state.




Figure 11: 100% wind turbine and 100% solar PV panel deployments to meet Vermont's 12.0 TWh/yr SEG

502 Total nameplate capacity requirements for meeting 12.0 TWh/year of electricity generation  
 503 rise sharply when implementing an all solar PV panel deployment as compared to a mixed  
 504 infrastructure scenario (see figure 12). Whereas just 4.3 GW<sub>AC</sub> of wind and solar PV infrastructure  
 505 is needed under the current ratio, maximum generation scenario, over 7.4 GW<sub>AC</sub> of new solar  
 506 PV panels are required under the solar PV-only, maximum generation scenario. In contrast, the  
 507 wind-only, maximum generation scenario requires less than 3 GW<sub>AC</sub> of new wind turbines to be  
 508 constructed.




Figure 12: Nameplate capacities of 12.0 TWh/yr SEG deployments. G: maximum generation siting; R: random placement; C: clustering.

509 Land use requirements of the wind-only and solar PV-only infrastructure deployments are  
 510 shown in figure 13. While many of the scenarios tested here produced infrastructure deployments  
 511 that spread over most or all of Vermont, none of the test scenarios resulted in total wind and solar  
 512 PV land use exceeding 1% (183 km<sup>2</sup>) of Vermont's eligible land. Among scenarios that site at  
 513 least some wind turbines, no scenario exceeded 0.5% of (92 km<sup>2</sup>) Vermont's eligible land. Once

514 again, wind turbines offer the highest nameplate capacity to direct land use efficiency in Vermont.  
 515 For example, the wind-only, maximum generation scenario occupies just 7.3 km<sup>2</sup> of land, less than  
 516 double the land occupied by all of Vermont’s existing wind and solar PV infrastructure.




Figure 13: Land use requirements for 12.0 TWh/yr SEG deployments. G: maximum generation siting; R: random placement; C: clustering.

#### 4.4 Assessing wind and solar PV deployments versus hourly load

517 Finally, we examine each wind and solar PV infrastructure deployment scenario for its performance  
 518 relative to real hourly Vermont load data. Modeled hourly electricity generation data for the years  
 519 2013 to 2017 are compared to real Vermont statewide hourly load data for the same period to  
 520 assess the effectiveness of all 21 test scenarios in satisfying hourly load in the absence of energy  
 521 storage and other electricity generation resources. Figure 14 shows that across all test scenarios  
 522 except for the 2.4 TWh/year and 100% solar PV deployments, maximum generation siting method  
 523 deployments yield increased annual load satisfaction of between 5 and 8% relative to random

524 siting and clustering siting method deployments. In the remaining two scenario groups, each siting  
 525 method yields nearly identical load satisfaction performance (approximately 43% and 52% of total  
 526 load met, respectively) but for different reasons. In the 2.4 TWh/year scenarios, there are very  
 527 few hours in which load is completely met by wind and solar PV, meaning that almost all of the  
 528 2.4 TWh of electricity generated per year by each configuration is used to meet load. As figure 15  
 529 confirms, only a negligible amount (less than 0.005 TWh [0.9%]) of annual electricity generation is  
 530 produced in excess of hourly load over the entire five year test period. Conversely, the 100% solar  
 531 PV scenarios generate enormous amounts of surplus electricity generation (in excess of 9 TWh  
 532 [75%]) per year. The over 7 GW<sub>AC</sub> of solar PV panels placed across Vermont in these scenarios  
 533 (see figure 12) easily meet and exceed Vermont’s hourly load during most daylight hours but are  
 534 incapable of generating electricity at night, thus leaving unavoidable deficits in load satisfaction.  
 535 Also of note is the inferior performance of the wind-only and solar PV-only scenarios relative to  
 536 the 12.0 TWh/year, current ratio scenarios. This result suggests that there are some advantages in  
 537 leveraging a mix of wind and solar PV infrastructure for satisfying load as compared to wind-only  
 538 and solar PV-only infrastructure deployments.




Figure 14: Mean annual Vermont load met by in-state wind and solar PV. G: maximum generation siting; R: random placement; I: Initial Configuration; C: clustering.




Figure 15: Mean annual surplus electricity generation for Vermont wind and solar PV versus hourly load. G: maximum generation siting; R: random placement; I: Initial Configuration; C: clustering.

539            Figures 14 and 15 also reveal that as increasing amounts of wind and solar PV infrastructure  
540 are installed, regardless of siting strategy, the marginal increases in load met by wind and solar  
541 PV decrease sharply. The approximately 2 GW<sub>AC</sub> of additional wind and solar PV nameplate  
542 capacity in the 6.3 TWh/year, maximum generation scenario relative to the initial wind and solar  
543 PV infrastructure configuration carries annual load met from 18.1% to 82.5%. The next 2 GW<sub>AC</sub> of  
544 additional wind and solar PV nameplate capacity needed to achieve the 12.0 TWh/year threshold  
545 yields only a 9.3% increase in annual load met to 91.8%. The principle cause of this pattern is the  
546 frequency of low wind, low (or no) sunlight weather conditions. Given an infinite amount of wind  
547 and solar PV infrastructure, there are some hours in which winds are calm, the sun does not shine,  
548 and wind and solar PV generators cannot produce electricity. These events, though infrequent,  
549 are inescapable hindrances for even large-scale wind and solar PV infrastructure deployments,  
550 particularly in relatively small geographic domains [38].

551            Figure 16 shows how each test scenario performs on a per-unit nameplate capacity basis  
552 with respect to overall electricity generation and load met. While electricity generation figures  
553 remain steady as each SEG is satisfied, marginal load satisfaction per unit of wind and solar PV



554 infrastructure decreases steadily. Load satisfaction efficiency drops from 1,900 kWh per kW<sub>AC</sub> in  
 555 the real-world initial configuration to just 1,200 kWh per kW<sub>AC</sub> in the 12.0 TWh/year, maximum  
 556 generation scenario. Even the 100% wind energy scenarios, where electricity generation per unit  
 557 capacity is well over 4,000 kWh per kW<sub>AC</sub>, suffer degraded per-unit load satisfaction efficiency  
 558 relative to the initial configuration. This trend comports with the diminishing marginal returns on  
 559 new wind and solar PV infrastructure discussed above.




Figure 16: Vermont wind and solar PV electricity generation and load satisfied per kW<sub>AC</sub> nameplate capacity.

## 5 Discussion

560 The foregoing case study demonstrates how more granular modeling of wind and solar PV  
561 infrastructure, the land use this infrastructure incurs, and the weather conditions this infrastructure  
562 relies upon for electricity generation can enable more realistic and tangible formulations of SEG-  
563 compatible electricity systems. The methods described here can be utilized anywhere in CONUS,  
564 provided that sufficient information about the location, size, and type of existing wind and solar  
565 PV infrastructure can be collected. Analyses of other states and regions in North America to  
566 compare and contrast with Vermont were hampered by the lack of datasets equivalent to [32]. The  
567 diversity of potential pathways for meeting SEGs and broader goals like the “rapid and far-reaching  
568 transitions” called for by the IPCC means that this work only represents one part of the process  
569 for finding and delivering a consensus electricity system decarbonization solution [1]. Moreover,  
570 the solution that works for one region or community may not work for another. Based on the  
571 outcomes of this case study, wind turbines appear to be a superior choice for meeting Vermont’s  
572 electricity needs in terms of operational efficiency (i.e. meeting electricity demand when it is  
573 demanded) and land use efficiency. This outcome should not be construed as a recommendation  
574 for Vermont to deploy wind turbines hastily or exclusively, nor is it a blueprint for the whole of  
575 North America to follow. Each region has different population levels, energy demand patterns,  
576 wind and sunlight resources, electric grid capacities, preferences, priorities, and so on; there is  
577 no one-size-fits-all solution. Instead, the Vermont case study demonstrates in general terms how  
578 the distance between energy policy goals and initial conditions can be bridged. The ultimate  
579 utility of this information is then unlocked when its findings are used to inform and initiate  
580 further analyses and stakeholder discussions. It is from these processes that the ultimate electricity  
581 system decarbonization pathways will be determined. To that end, we will now discuss a range of  
582 additional topics that interlock with and overlap the work undertaken here.

583         As noted, the Vermont case study shows that, among the three infrastructure types modeled,  
584 wind turbines provided both large, consistent electricity generation returns and minimal direct  
585 land use impacts. This will also be true of other regions of North America that have strong wind

586 resources and particularly true of other locations with similar or lower quality sunlight resources.  
587 The full landscape impacts of wind energy are not fully captured in the above case study, however.  
588 As discussed briefly in section 2.3, wind turbine towers only directly occupy small parcels of land.  
589 Secondary land uses, both temporary and permanent, due to site preparation, service roads, and  
590 support infrastructure can significantly expand the true footprint of wind turbine installations. The  
591 visual impacts of wind turbine towers and rotating blades are also not captured in the model. These  
592 impacts represent a significant source of resistance to wind turbine siting among communities in  
593 Vermont and elsewhere. While the REGS model uses a rudimentary measure of wind turbine  
594 crowding to prevent oversaturation, it does not capture the potential visual impacts of wind turbines  
595 which undoubtedly influence the viability of some locations for receiving wind turbines [39] [40].  
596 This is particularly true for many of the highest electricity generation locations in Vermont which  
597 are also typically the highest elevation locations in Vermont and therefore among the most visible  
598 locations in Vermont. Making like for like comparisons between wind turbines and solar PV panels  
599 in terms of land use is thus a somewhat flawed exercise. Better capturing the total landscape-level  
600 impacts of wind energy in future modeling iterations is a worthy area for future work.

601 Another key aspect of new energy infrastructure deployments to consider is the lifespan  
602 of the infrastructure. Like any other infrastructure type, wind turbines and solar PV panels have  
603 limited effective lifespans and must be replaced periodically. Wind turbines and solar PV panels  
604 typically have lifespans of between 20 and 30 years [41]. Once a wind turbine or solar PV panel  
605 array is due to be replaced, its electricity generation capacity is lost until new infrastructure is  
606 installed or a new installation is made elsewhere. This process is not captured in the REGS model  
607 since the model develops individual snapshots of infrastructure deployments rather than timeseries.  
608 While infrastructure replacement means that more efficient wind turbines or solar PV panels can  
609 be installed, it also allows for land leases to expire and generation capacity to be lost. Capturing  
610 these factors in future modeling activities could also enhance the utility of this work.

611 Rooftop solar PV panels are not distinguished from ground-mounted solar PV panels in this  
612 case study which means that rooftop solar PV panels incur land use. Quantifying rooftop solar PV

613 panel siting suitability and electricity generation potential is an active area of research [42] [43].  
614 More explicit modeling of rooftop PV panel siting could both improve the accuracy of the model  
615 and reduce the modeled land use footprint of solar PV panel infrastructure. This could enhance  
616 the relative strength of solar PV panels against wind turbines in land use efficiency evaluations and  
617 provide better estimates of a given region's potential rooftop solar PV capacity. Rooftop solar PV  
618 panels can also partially or completely meet local household electricity demand in some situations  
619 and, in aggregate, significantly influence the grid's net electricity demand levels. As rooftop solar  
620 PV panels and other 'behind the meter' energy resources become more prevalent, more elaborate  
621 modeling techniques for electricity demand would be worthy additions to analyses like this one.

622 Energy storage technologies, particularly batteries and electric vehicles, are also likely  
623 to significantly influence the growth and behavior of electricity systems. These technologies,  
624 along with generally growing electricity demand through electrification of non-electric energy  
625 consumption behaviors, will likely mean that some of the surplus electricity generated by the  
626 larger wind and solar PV infrastructure deployments tested above (15) could be harnessed rather  
627 than wasted through curtailment. At present, if too much electricity is fed into the grid by wind  
628 and solar PV generators, they may be instructed to curtail their generation so as not endanger other  
629 grid infrastructure through overloading. This is counterproductive for a number of reasons. For  
630 example, curtailed wind and solar PV electricity reduces the economic competitiveness of these  
631 energy resources and reduces the use of low-carbon and carbonless electricity generators. Energy  
632 storage technologies can absorb excess electricity at times of peak generation and help redistribute  
633 energy back into the grid during times of peak load. These devices would improve the efficacy of  
634 wind turbines and solar PV panels in meeting load and could reduce the amount of total nameplate  
635 generation capacity needed to fulfill electricity demands. This would, in turn, reduce the landscape  
636 impacts of electricity systems as a whole.

637 We have elected not to incorporate energy storage in this work as we feel it would  
638 significantly extend the scope of the work, add substantial modeling complexity, and stray from

639 the paper’s core purpose of assessing SEGs<sup>4</sup>. Instead, we feel this paper best serves as an enabler  
640 of further modeling and analysis in more focused areas, particularly power systems analysis, by  
641 grid operators, regulators, or other relevant stakeholders. Modeling of energy storage in this paper  
642 would entail making additional assumptions about future electricity load patterns, electric vehicle  
643 adoption, and interstate electricity trade. In addition, were large quantities of energy source  
644 capacity added to the grid, it is possible that their introduction would introduce a range of grid  
645 operation impacts across both the bulk transmission grid and local distribution lines. These topics  
646 represent significant additional work and their inclusion in this paper would further complicate the  
647 presentation of the scenarios tested which are already multifaceted with respect to infrastructure  
648 type, distribution, land use impacts, and performance relative to load.

649 We have also elected not to undertake explicit mathematical optimization analyses in this  
650 paper for similar reasons. As with the energy storage case, introducing optimization methods  
651 to the suite of test scenarios represents a significant extension of this paper’s scope. Identifying  
652 optimal placements of new wind and solar PV infrastructure to meet SEGs with respect to one or  
653 more geospatial parameters, the electric grid, economic criteria, or other constraints is a worthy  
654 task, but one which can easily stand on its own in a separate paper. We believe this paper’s  
655 outcomes and methods can be used to facilitate and more richly inform these efforts, particularly  
656 those undertaken by RTOs and ISOs. Specifically, we also believe that optimization with respect  
657 to certain parameters (e.g. maximizing electricity generation) could lead to overfitted solutions  
658 that are unlikely to be feasible to implement. For example, if a strictly optimal solar PV panel  
659 deployment were identified, the resulting infrastructure placements would fully saturate the 3km  
660 by 3km grid boxes that have the global maximum mean annual solar PV electricity generation  
661 potential and leave all other grid boxes unaltered, even those with only marginally inferior sunlight  
662 resources.

---

<sup>4</sup>Vermont’s SEGs are technology agnostic and make no mention of energy storage technologies. Given the potential of energy storage devices in supporting the deployment and utilization of wind and solar PV generation resources, it is possible that energy storage capacity requirements may be included in future SEGs in Vermont and elsewhere.

## 6 Conclusion

663 Deployment of renewable, low-carbon energy resources like wind and solar PV is already well  
664 underway in many parts of the world due to concerns over climate change, environmental and  
665 human health, and energy security. Governments are ratifying increasingly stringent SEGs to  
666 accelerate this process. Decarbonizing the electric grid and other energy demands through  
667 electrification will require orders of magnitude more wind and solar PV infrastructure to be  
668 installed, Understanding how distributed, intermittent electricity generators will impact the  
669 landscape and the grid is essential for streamlining the wind and solar PV implementation process.

670 This paper translates SEGs ratified by governments into a portfolio of specific, SEG-  
671 compliant wind and solar PV configurations and uses the state of Vermont as a case study. Each  
672 of the four SEGs examined can be achieved by wind and solar PV infrastructure configurations  
673 that directly occupy less than 1% of the state's land area. Vermont electricity demand was most  
674 effectively met by infrastructure configurations that prioritize electricity generation over other  
675 siting criteria. Configurations that relied solely on solar PV tended to perform least effectively  
676 versus electricity demand patterns and occupy the most land, while wind-only configurations  
677 were only marginally less effective in meeting demand than mixed configurations reflecting the  
678 state's current wind and solar PV infrastructure ratios. Diminishing returns in electricity demand  
679 satisfaction were observed across all configurations as they grew in total nameplate capacity,  
680 highlighting the inherent limitations of intermittent electricity generation resources.

681 Opportunities to extend and improve the efficacy of the REGS model include utilizing  
682 additional geospatial infrastructure siting criteria such as land use type, viewshed impacts, access  
683 to existing transmission infrastructure, wildlife habitat and migration zone protection, and so  
684 on. These indirect land use impacts are particularly important to capture for wind energy since  
685 the direct land use footprint of wind turbines per  $MW_{AC}$  of generation capacity is minuscule as  
686 compared to solar PV panels. Incorporating wind and solar PV infrastructure lifespan limits,  
687 energy storage technologies, and rooftop solar PV panel siting could also enhance the utility of  
688 modeling results and provide more information to electric grid stakeholders of all types.

## 689 **Acknowledgements**

690 The authors thank Brian Voigt, Paul Hines, and Jon D. Erickson for their feedback and  
691 recommendations during the development of this work. This paper was supported by funding  
692 from the National Science Foundation's IGERT Program through Award Number 1144388.

## References

- [1] Intergovernmental Panel on Climate Change. *Global Warming of 1.5C - Summary for Policymakers*. Oct. 8, 2018.
- [2] Arthouros Zervos and Rana Adib. *Renewables 2018: Global Status Report*. 2018. ISBN: 978-3-9818911-3-3.
- [3] Atlanta, Georgia City Council. *A resolution by councilmember kwanza hall of the atlanta city council to adopt a vision of 100% clean energy powering the city of atlanta's needs by 2035; and for other purposes*. May 1, 2017.
- [4] Vermont Department of Public Service. *Vermont Comprehensive Energy Plan 2016*. Montpelier, Vermont, USA: Vermont Public Service Department, 2016.
- [5] United Nations Framework Convention on Climate Change. *Paris Agreement*. Dec. 12, 2015.
- [6] Thomas Ackermann et al. "Optimising the European transmission system for 77% renewable electricity by 2030". In: *IET Renewable Power Generation* 10.1 (Jan. 1, 2016), pp. 3–9. ISSN: 1752-1416, 1752-1424. DOI: 10.1049/iet-rpg.2015.0135.
- [7] Arman Aghahosseini et al. "Analysing the feasibility of powering the Americas with renewable energy and inter-regional grid interconnections by 2030". In: *Renewable and Sustainable Energy Reviews* 105 (May 2019), pp. 187–205. ISSN: 13640321. DOI: 10.1016/j.rser.2019.01.046.
- [8] Sarah Becker et al. "Features of a fully renewable US electricity system: Optimized mixes of wind and solar PV and transmission grid extensions". In: *Energy* 72 (Aug. 2014), pp. 443–458. ISSN: 03605442. DOI: 10.1016/j.energy.2014.05.067.
- [9] Cory Budischak et al. "Cost-minimized combinations of wind power, solar power and electrochemical storage, powering the grid up to 99.9% of the time". In: *Journal of Power*



- 717 *Sources* 225 (Mar. 2013), pp. 60–74. ISSN: 03787753. DOI: 10.1016/j.jpowsour.  
718 2012.09.054.
- 719 [10] Hans Christian Gils et al. “Integrated modelling of variable renewable energy-based power  
720 supply in Europe”. In: *Energy* 123 (Mar. 2017), pp. 173–188. ISSN: 03605442. DOI: 10.  
721 1016/j.energy.2017.01.115.
- 722 [11] James Nelson et al. “High-resolution modeling of the western North American power system  
723 demonstrates low-cost and low-carbon futures”. In: *Energy Policy* 43 (Apr. 2012), pp. 436–  
724 447. ISSN: 03014215. DOI: 10.1016/j.enpol.2012.01.031.
- 725 [12] Katrin Schaber, Florian Steinke, and Thomas Hamacher. “Transmission grid extensions for  
726 the integration of variable renewable energies in Europe: Who benefits where?” In: *Energy*  
727 *Policy* 43 (Apr. 2012), pp. 123–135. ISSN: 03014215. DOI: 10.1016/j.enpol.2011.  
728 12.040.
- 729 [13] B. Tamimi, C. Canizares, and K. Bhattacharya. “System Stability Impact of Large-Scale  
730 and Distributed Solar Photovoltaic Generation: The Case of Ontario, Canada”. In: *IEEE*  
731 *Transactions on Sustainable Energy* 4.3 (July 2013), pp. 680–688. ISSN: 1949-3029, 1949-  
732 3037. DOI: 10.1109/TSTE.2012.2235151.
- 733 [14] Doug Arent et al. “Implications of high renewable electricity penetration in the U.S. for  
734 water use, greenhouse gas emissions, land-use, and materials supply”. In: *Applied Energy*  
735 123 (June 2014), pp. 368–377. ISSN: 03062619. DOI: 10.1016/j.apenergy.2013.  
736 12.022.
- 737 [15] Rebecca R. Hernandez, Madison K. Hoffacker, and Christopher B. Field. “Efficient use  
738 of land to meet sustainable energy needs”. In: *Nature Climate Change* 5.4 (Apr. 2015),  
739 pp. 353–358. ISSN: 1758-678X, 1758-6798. DOI: 10.1038/nclimate2556.
- 740 [16] Mark Z. Jacobson et al. “100% Clean and Renewable Wind, Water, and Sunlight All-Sector  
741 Energy Roadmaps for 139 Countries of the World”. In: *Joule* 1.1 (Sept. 2017), pp. 108–121.  
742 ISSN: 25424351. DOI: 10.1016/j.joule.2017.07.005.

- 743 [17] Marc J.R. Perez and Vasilis M. Fthenakis. “On the spatial decorrelation of stochastic solar  
744 resource variability at long timescales”. In: *Solar Energy* 117 (July 2015), pp. 46–58. ISSN:  
745 0038092X. DOI: 10.1016/j.solener.2015.04.020.
- 746 [18] F.J. Santos-Alamillos et al. “Do current wind farms in Spain take maximum advantage of  
747 spatiotemporal balancing of the wind resource?” In: *Renewable Energy* 96 (Oct. 2016),  
748 pp. 574–582. ISSN: 09601481. DOI: 10.1016/j.renene.2016.05.019.
- 749 [19] Juliet E. Carlisle et al. “Public attitudes regarding large-scale solar energy development in  
750 the U.S.” In: *Renewable and Sustainable Energy Reviews* 48 (Aug. 2015), pp. 835–847.  
751 ISSN: 13640321. DOI: 10.1016/j.rser.2015.04.047.
- 752 [20] Chad Walker, Jamie Baxter, and Danielle Ouellette. “Beyond Rhetoric to Understanding  
753 Determinants of Wind Turbine Support and Conflict in Two Ontario, Canada Communities”.  
754 In: *Environment and Planning A: Economy and Space* 46.3 (Mar. 2014), pp. 730–745. ISSN:  
755 0308-518X, 1472-3409. DOI: 10.1068/a130004p.
- 756 [21] Eric P. James, Stanley G. Benjamin, and Melinda Marquis. “A unified high-resolution  
757 wind and solar dataset from a rapidly updating numerical weather prediction model”. In:  
758 *Renewable Energy* 102 (Mar. 2017), pp. 390–405. ISSN: 09601481. DOI: 10.1016/j.  
759 renene.2016.10.059.
- 760 [22] Y H Wan, E Ela, and K Orwig. “Development of an Equivalent Wind Plant Power-Curve”.  
761 In: *WindPower 2010*. Dallas, TX, USA, June 2010, p. 23.
- 762 [23] John Twidell and Anthony D. Weir. *Renewable Energy Resources*. 2nd ed. OCLC:  
763 ocm60500429. London ; New York: Taylor & Francis, 2006. 601 pp. ISBN: 978-0-419-  
764 25320-4.
- 765 [24] John A. Duffie and William A. Beckman. *Solar Engineering of Thermal Processes*.  
766 Hoboken, NJ, USA: John Wiley & Sons, Inc., Apr. 10, 2013. ISBN: 978-1-118-67160-3.  
767 DOI: 10.1002/9781118671603.

- 768 [25] Bernhard Haurwitz. “Insolation in Relation to Cloudiness and Cloud Density”. In: *Journal*  
769 *of Meteorology* 2.3 (Sept. 1945), pp. 154–166. ISSN: 0095-9634, 0095-9634. DOI: 10 .  
770 1175/1520-0469 (1945) 002<0154:IIRTCA>2.0.CO;2.
- 771 [26] Sean Ong et al. *Land-use requirements for solar power plants in the United States*.  
772 NREL/TP-6A20-56290. National Renewable Energy Laboratory, 2013.
- 773 [27] Paul Denholm et al. *Land-use requirements of modern wind power plants in the United*  
774 *States*. NREL/TP-6A2-45834. National Renewable Energy Laboratory, 2009.
- 775 [28] US Energy Information Agency. *Vermont - State Energy Profile Analysis*. July 2018. URL:  
776 <https://www.eia.gov/state/analysis.php?sid=VT> (visited on  
777 11/26/2018).
- 778 [29] Vermont Center for Geographic Information. *VT USGS DEM (1 degree)*. Vermont Open  
779 Geodata Portal. Apr. 2019. URL: [https://maps.vcgi.vermont.gov/gisdata/  
780 vcgi/packaged\\_zips/ElevationDEM\\_DEM250.zip](https://maps.vcgi.vermont.gov/gisdata/vcgi/packaged_zips/ElevationDEM_DEM250.zip).
- 781 [30] United States Geological Survey. *One Million-Scale Waterbodies and Wetlands of the*  
782 *United States*. The National Map Small Scale. 2014. URL: [https://nationalmap.  
783 gov/small\\_scale/mld/1lakesp.html](https://nationalmap.gov/small_scale/mld/1lakesp.html).
- 784 [31] Vermont Center for Geographic Information. *VT Protected Lands Database*. Vermont Open  
785 Geodata Portal. June 2016. URL: [http://geodata.vermont.gov/datasets/  
786 072bb8ad3c454b0e9cb0f517e9a296a3\\_10](http://geodata.vermont.gov/datasets/072bb8ad3c454b0e9cb0f517e9a296a3_10).
- 787 [32] Energy Action Network. *Renewable Energy Atlas of Vermont*. 2010. URL: [https://www.  
788 vtenergydashboard.org/energy-atlas](https://www.vtenergydashboard.org/energy-atlas).
- 789 [33] US Energy Information Agency. *Electric Power Monthly with data for December 2018*.  
790 2019.
- 791 [34] US Energy Information Agency. *Total End-Use Energy Consumption Estimates, 2016*. June  
792 2018.

- 793 [35] ISO New England. *Hourly Wholesale Load Cost Reports*. Oct. 2018.
- 794 [36] Amit Kumar Yadav and S.S. Chandel. “Tilt angle optimization to maximize incident solar  
795 radiation: A review”. In: *Renewable and Sustainable Energy Reviews* 23 (July 2013),  
796 pp. 503–513. ISSN: 13640321. DOI: 10.1016/j.rser.2013.02.027.
- 797 [37] Jayanta Deb Mondol, Yigzaw G. Yohanis, and Brian Norton. “Optimal sizing of array and  
798 inverter for grid-connected photovoltaic systems”. In: *Solar Energy* 80.12 (Dec. 2006),  
799 pp. 1517–1539. ISSN: 0038092X. DOI: 10.1016/j.solener.2006.01.006.
- 800 [38] Poul A. Østergaard. “Geographic aggregation and wind power output variance in Denmark”.  
801 In: *Energy* 33.9 (Sept. 2008), pp. 1453–1460. ISSN: 03605442. DOI: 10.1016/j.  
802 energy.2008.04.016.
- 803 [39] Nicole Pidala. “Public Perceptions of Wind Energy in Vermont: The Role of Physical,  
804 Social, and Environmental Parameters in the Vermont Wind Energy Debate”. PhD thesis.  
805 University of Vermont, 2017.
- 806 [40] Bill Opalka. “Why this dairy farm may be the last stand for wind energy in Vermont”. In:  
807 *Energy News Network* (Oct. 3, 2018).
- 808 [41] Vasilis Fthenakis and Hyung Chul Kim. “Land use and electricity generation: A life-cycle  
809 analysis”. In: *Renewable and Sustainable Energy Reviews* 13.6 (Aug. 2009), pp. 1465–1474.  
810 ISSN: 13640321. DOI: 10.1016/j.rser.2008.09.017.
- 811 [42] L.K. Wiginton, H.T. Nguyen, and J.M. Pearce. “Quantifying rooftop solar photovoltaic  
812 potential for regional renewable energy policy”. In: *Computers, Environment and Urban*  
813 *Systems* 34.4 (July 2010), pp. 345–357. ISSN: 01989715. DOI: 10.1016/j.  
814 compenvurbsys.2010.01.001.
- 815 [43] Pieter Gagnon et al. “Estimating rooftop solar technical potential across the US using a  
816 combination of GIS-based methods, lidar data, and statistical modeling”. In: *Environmental*  
817 *Research Letters* 13.2 (Feb. 1, 2018), p. 024027. ISSN: 1748-9326. DOI: 10.1088/1748-  
818 9326/aaa554.